

Nr pom.	Nazwa pomieszczenia	Powierzchnia [m2]	Wysokość [m]	Kubatura pomieszczenia [m3]	Ilość wymian [w]	Ilość powietrza [m3]	Ilość osób	Ilość powietrza [m3/os/h]	Ilość powietrza [m3]	Przyjęto	Pow. nawiew [m3/h]	Pow. wywiew [m3/h]	UKŁAD	
1.1	Kl. Schodowa	35,75	3,20	114,40	0,5	57	-	-	-	60	60	130	N2W2	dodano /U z parteru do klatki schodowej
1.2	Korytarz	66,91	3,20	214,11	0,5	107	-	-	-	110	110	85	N2W2	
1.3	Sekretariat	11,65	3,20	37,28	0,5	19	-	-	-	25	25		N2W2	
1.4	Magazyn	3,69	3,20	11,81	0,5	6	-	-	-	25	25	25	N2W2	
1.5	Zaplecze socjalne	10,04	3,20	32,13	2	64	4	30	120	100	100	100	N2W2	
1.6	Korytarz	31,71	3,20	101,47	0,5	51	-	-	-	50	50	50	N2W2	
1.7	Sala konferencyjna	34,92	3,20	111,74	2	223	16	30	480	480	480	480	N2W2	
1.8	Pokój koordynatora	16,57	3,20	53,02	2	106	1	30	30	100	100	100	N2W2	
1.9	Pokój koordynatora	12,98	3,20	41,54	2	83	1	30	30	100	100	100	N2W2	
1.10	Pokój koordynatora	18,11	3,20	57,95	2	116	1	30	30	100	100	100	N2W2	
1.11	Pokój koordynatora	15,54	3,20	49,73	2	99	1	30	30	100	100	100	N2W2	
1.12	Pokój prezesa	20,17	3,20	64,54	2	129	1	30	30	100	100	100	N2W2	
1.13	Sala konferencyjna	34,93	3,20	111,78	2	224	16	30	480	480	480	480	N2W2	
1.14	Pom. Fizjoterapii	68,02	3,20	217,66	2	435	8	30	240	435	435	435	N1 W2	Living HP20
1.15	Łazienka D	6,59	3,20	21,09	8	169	1	30	30	150		175	W2	Living HP20
1.16	Szatnia D	9,00	3,20	28,80	6	173	7	30	210	175	150		N1W1	
1.17	Łazienka M	5,27	3,20	16,86	8	135	1	30	30	150		200	W2	Living HP20
1.18	Szatnia M	10,39	3,20	33,25	6	199	8	30	240	200	150		N1W1	
1.19	Kl. Schodowa	17,42	3,20	55,74	0,5	28	-	-	-	55	85		N2W2	dodano z5 z parteru do klatki schodowej
1.20	Korytarz	15,33	3,20	49,06	0,5	25	-	-	-	30		35	N2W2	
1.21	Pom. odnowy biologicznej	57,70	3,20	184,64	8	1477	10	30	300	1500	1500	1500	N1W1	
1.22	Sala ćwiczeń	129,78	3,20	415,30	3	1246	15	50	750	1000	1000	1000	N1W1	
1.23	Siłownia	200,74	3,20	642,37	3	1927	25	100	2500	2500	2500	2500	N1W1	

1.24	Świetlica	34,65	3,20	110,89	2	222	12	30	360	360	360	360	N2W2
1.25	Kawiarnia	142,74	3,20	456,77	2	914	30	30	900	900	900	850	N2W2
1.26	Zaplecze	12,16	3,20	38,91	1	39	-	-	-	50		50	N2W2
1.29	WC	10,97	3,20	35,10	4	140	3	30	90	125		125	W4
1.30	WC M	7,43	3,20	23,78	4	95	3	30	90	100	100		N1W1
1.31	WC	6,73	3,20	21,54	4	86	3	30	90	100		100	W4
1.32	WC D	5,54	3,20	17,73	4	71	3	30	90	75	75		N1W1
1.33	Pokój rozmów	12,65	3,20	40,48	2	81	4	30	120	120	120	120	N2W2

Living HP20

Living HP20

Σ= 9205 9300

N1W1	5910	5000
N2W2	3295	3265
W2		810
W4		225

living  
living